

39th Ave Pump Report

Irrigation Dates	Actual GPM	Design GPM	% of Flow		
5/1/2017	2240	2400	93%	2017 Total Pump Hours Ran 491.30 Total Gallons Pumped 70,833,000 Acre Foot of Water 217.36	
5/8/2017	2196	2400	92%		
5/15/2017	2206	2400	92%		
5/22/2017	2178	2400	91%		
5/30/2017	2173	2400	91%		
6/5/2017	2153	2400	90%		
6/12/2017	2201	2400	92%		
6/19/2017	2045	2400	85%		
6/26/2017	2138	2400	89%		
7/5/2017	2083	2400	87%		
7/10/2017	2121	2400	88%		
7/17/2017	2121	2400	88%		
7/27/2017	2112	2400	88%		
7/3/2017	2051	2400	85%		
8/7/2017	1923	2400	80%		pump down
		2400			
8/28/2017	1979	2400	82%		
9/5/2017	2021	2400	84%		
9/11/2017	2002	2400	83%		
9/18/2017	2043	2400	85%		
9/25/2017	2049	2400	85%		
10/2/2017	2054	2400	86%		
10/9/2017	2055	2400	86%		
10/16/2017	2064	2400	86%		
12/6/2017	2284	2400	95%		
12/11/2017	2299	2400	96%		
1/2/2018	2002	2400	83%		
1/8/2018	2019	2400	84%		
1/22/2018	2022	2400	84%		
1/29/2018	2339	2400	97%		
2/12/2018	2189	2400	91%		
2/19/2018	2189	2400	91%		
3/5/2018	2248	2400	94%		
3/12/2018	2439	2400	102%		
3/26/2018	2405	2400	100%		
4/2/2018	2410	2400	100%		
4/9/2018	2409	2400	100%		
4/16/2018	2407	2400	100%		
4/23/2018	1633	2400	68%		
4/30/2018	11790	2400	491%		
5/7/2018	2418	2400	101%		
5/14/2018	2413	2400	101%		
5/21/2018	2415	2400	101%		
5/29/2018	2409	2400	100%		
6/4/2018	-190498	2400	-7937%		
6/11/2018	2397	2400	100%		
6/18/2018	2401	2400	100%		

6/25/2018	2565	2400	107%
7/2/2018	2179	2400	91%
7/5/2018	2349	2400	98%
7/9/2018	2387	2400	99%
7/16/2018	2423	2400	101%
7/23/2018	88340	2400	3681%
7/30/2018	944	2400	39%
8/6/2018	2359	2400	98%
8/13/2018	2410	2400	100%
8/20/2018	2401	2400	100%
8/27/2018	2404	2400	100%
9/4/2018	2401	2400	100%
9/10/2018	2402	2400	100%
9/17/2018	2402	2400	100%
9/24/2018	2403	2400	100%

43rd Ave Pump Report

Irrigation Dates	Actual GPM	Design GPM	% of Flow	
5/1/2017	2338	2400	97%	2017
5/15/2017	2342	2400	98%	Total Pump Hours Ran
5/22/2017	2343	2400	98%	2113.10
5/30/2017	2330	2400	97%	Total Gallons Pumped
6/5/2017	2341	2400	98%	284,737,000
6/12/2017	2322	2400	97%	Acre Foot of Water
6/19/2017	2318	2400	97%	873.77
6/26/2017	2323	2400	97%	
7/5/2017	2270	2400	95%	
7/10/2017	2329	2400	97%	
7/17/2017	2331	2400	97%	
7/24/2017	2316	2400	97%	
7/31/2017	2272	2400	95%	
8/7/2017	2338	2400	97%	
8/22/2017	2360	2400	98%	
8/28/2017	2321	2400	97%	
9/5/2017	2327	2400	97%	
9/11/2017	2317	2400	97%	
9/18/2017	2329	2400	97%	
9/25/2017	2322	2400	97%	
10/2/2017	2278	2400	95%	
10/9/2017	2343	2400	98%	
10/16/2017	2339	2400	97%	
10/23/2017	2333	2400	97%	
11/6/2017	2339	2400	97%	
11/13/2017	2344	2400	98%	
12/5/2017	2334	2400	97%	
12/11/2017	2341	2400	98%	
1/2/2018	2333	2400	97%	
1/8/2018	2210	2400	92%	
1/22/2018	2266	2400	94%	
1/29/2018	1415	2400	59%	
2/12/2018	2187	2400	91%	
2/19/2018	2304	2400	96%	
3/5/2018	2225	2400	93%	
3/12/2018	2305	2400	96%	
3/26/2018	2313	2400	96%	
4/2/2018	2295	2400	96%	
4/9/2018	2275	2400	95%	
4/16/2018	2284	2400	95%	
4/23/2018	2302	2400	96%	
4/30/2018	2322	2400	97%	
5/7/2018	2320	2400	97%	
5/14/2018	2273	2400	95%	
5/21/2018	-319	2400	-13%	
5/29/2018	358	2400	15%	
6/4/2018	2238	2400	93%	

6/11/2018	2198	2400	92%
6/18/2018	2247	2400	94%
6/25/2018	2232	2400	93%
7/2/2018	1993	2400	83%
7/5/2018	2588	2400	108%
7/9/2018	1951	2400	81%
7/16/2018	2124	2400	88%
7/23/2018	2537	2400	106%
7/30/2019	1777	2400	74%
8/6/2018	2178	2400	91%
8/13/2018	2254	2400	94%
8/20/2018	2190	2400	91%
8/27/2018	2236	2400	93%
9/4/2018	2219	2400	92%
9/10/2018	2245	2400	94%
9/17/2018	2213	2400	92%
9/24/2018	2253	2400	94%