

39th Ave Pump Report

Irrigation Dates	Actual GPM	Design GPM	% of Flow	
7/2/2012	2143	2250	95%	2013
7/9/2012	2145	2250	95%	Total Pump Hours Ran
7/16/2012	2148	2250	95%	2481.90
7/23/2012	2144	2250	95%	Total Gallons Pumped
7/30/2012	2151	2250	96%	360,393,000
8/7/2012	2141	2250	95%	Acre Foot of Water
8/13/2012	2148	2250	95%	1105.93
8/20/2012	2149	2250	95%	
9/4/2012	2158	2250	96%	
9/10/2012	2161	2250	96%	
9/17/2012	2157	2250	96%	
9/24/2012	2156	2250	96%	
10/1/2012	2160	2250	96%	
10/8/2012	2155	2250	96%	
10/15/2012	2166	2250	96%	
10/22/2012	2161	2250	96%	
10/29/2012	2162	2250	96%	
11/5/2012	2162	2250	96%	
11/12/2012	2162	2250	96%	
11/26/2012	2169	2250	96%	
12/3/2012	2172	2250	97%	
1/23/2013	2497	2400	104%	
2/11/2013	2495	2400	104%	
2/18/2013	2494	2400	104%	
3/4/2013	2483	2400	103%	
3/11/2013	2487	2400	104%	
3/25/2013	2477	2400	103%	
4/2/2013	2465	2400	103%	
4/8/2013	2470	2400	103%	
4/15/2013	2479	2400	103%	
4/22/2013	2475	2400	103%	
4/29/2013	2458	2400	102%	
5/6/2013	2465	2400	103%	
5/13/2013	2469	2400	103%	
5/27/2013	2458	2400	102%	
6/3/2013	2471	2400	103%	
6/10/2013	2407	2400	100%	
6/17/2013	2433	2400	101%	
6/25/2013	2430	2400	101%	
7/1/2013	2425	2400	101%	
7/12/2013	2435	2400	101%	
7/15/2013	2426	2400	101%	
7/22/2013	2461	2400	103%	
7/29/2013	2418	2400	101%	

8/6/2013	2211	2400	92%	
8/12/2013	2203	2400	92%	
8/19/2013	2150	2400	90%	
9/3/2013	2302	2400	96%	
9/9/2013	2300	2400	96%	30min + big rain
9/25/2013	2301	2400	96%	
9/30/2013	2330	2400	97%	
10/7/2013	2430	2400	101%	
10/9/2013	2457	2400	102%	
10/14/2013	2288	2400	95%	
10/21/2013	2258	2400	94%	
10/28/2013	2362	2400	98%	

43rd Ave Pump Report

Irrigation Dates	Actual GPM	Design GPM	% of Flow	
7/2/2012	2285	2250	102%	
7/9/2012	2287	2250	102%	
7/16/2012	2288	2250	102%	
7/23/2012	2288	2250	102%	
7/30/2012	2289	2250	102%	
8/6/2012	2286	2250	102%	
8/13/2012	2283	2250	101%	
8/20/2012	2289	2250	102%	
9/4/2012	2290	2250	102%	
9/10/2012	2299	2250	102%	
9/17/2012	2293	2250	102%	
9/24/2012	2293	2250	102%	
10/1/2012	2313	2250	103%	
10/8/2012	2308	2250	103%	
10/16/2012	2305	2250	102%	
10/22/2012	2315	2250	103%	
10/29/2012	2313	2250	103%	
11/5/2012	2316	2250	103%	
11/12/2012	2315	2250	103%	
11/26/2012	2325	2250	103%	
12/3/2012	2325	2250	103%	
1/14/2013	2345	2250	104%	
1/23/2013	2339	2250	104%	
2/11/2013	2341	2250	104%	
2/18/2013	2331	2250	104%	
3/4/2013	2313	2250	103%	
3/11/2013	2323	2250	103%	
3/25/2013	2314	2250	103%	
4/1/2013	2310	2250	103%	
4/8/2013	2313	2250	103%	
4/15/2013	2306	2250	102%	
6/6/2013	2041	2250	91%	pump failed
6/10/2013	2052	2250	91%	
6/18/2013	2052	2250	91%	
6/24/2013	2078	2250	92%	
7/1/2013	2050	2250	91%	
7/12/2013	2088	2250	93%	
7/15/2013	2083	2250	93%	
7/22/2013	2079	2250	92%	
7/29/2013	2078	2250	92%	
8/5/2013	2112	2250	94%	
8/12/2013	2079	2250	92%	
8/19/2013	2096	2250	93%	
9/3/2013	2090	2250	93%	

2013

Total Pump Hours Ran

2118.20

Total Gallons Pumped

274,051,000

Acre Foot of Water

840.98

9/9/2013	2234	2250	99%	4 hr big rain
9/23/2013	2103	2250	93%	
9/30/2013	2098	2250	93%	
10/7/2013	2110	2250	94%	
10/14/2013	2072	2250	92%	
10/21/2013	2094	2250	93%	
10/28/2013	2080	2250	92%	

Mileage Report

Date	Lines	Pumps	Miles
7/2/2012	1-4, 11-18	39th & 43rd	690
7/9/2012	5-6,7-10	39th & 43rd	429
7/16/2012	1-4, 11-18	39th & 43rd	646
7/23/2012	5-6, 7-10	39th & 43rd	631
7/30/2012	1-4, 11-18	39th & 43rd	639
8/7/2012	5-6, 7-10	39th & 43rd	544
8/13/2012	1-4, 11-18	39th & 43rd	620
8/20/2012	5-6, 7-10	39th & 43rd	234
9/4/2012	1-4, 11-18	39th & 43rd	587
9/10/2012	5-6, 7-10	39th & 43rd	527
9/17/2012	1-4, 11-18	39th & 43rd	524
9/24/2012	5-6, 7-10	39th & 43rd	502
10/1/2012	1-4, 11-18	39th & 43rd	716
10/8/2012	5-6, 7-10	39th & 43rd	330
10/15/2012	1-4, 11-18	39th & 43rd	490
10/22/2012	5-6, 7-10	39th & 43rd	437
10/29/2012	1-4, 11-18	39th & 43rd	485
11/5/2012	5-6, 7-10	39th & 43rd	429
11/12/2012	1-4, 11-18	39th & 43rd	495
11/26/2012	5-6, 7-10	39th & 43rd	509
12/3/2012	1-4, 11-18	39th & 43rd	486
1/14/2013	5-10	43rd only	598
1/23/2013	1-4, 11-18	39th & 43rd	579
2/11/2013	5-6, 7-10	39th & 43rd	433
2/18/2013	1-4, 11-18	39th & 43rd	382
3/4/2013	5-6, 7-10	39th & 43rd	432
3/11/2013	1-4, 11-18	39th & 43rd	398
3/25/2013	5-6, 7-10	39th & 43rd	400
4/2/2013	1-4, 11-18	39th & 43rd	464
4/8/2013	5-6, 7-10	39th & 43rd	416
4/15/2013	1-4, 11-18	39th & 43rd	628
4/22/2013	5-10	39th only	661
4/29/2013	1-4,11-18	39th only	656
5/6/2013	5-10	39th only	690
5/13/2013	1-4, 11-18	39th only	911
5/27/2013	5-10	39th only	469
6/3/2013	5-6,11-18, 1-4	39th & 43rd	545
6/10/2013	5-6, 7-10	39th & 43rd	355
6/17/2013	11-18,5, 1-4	39th & 43rd	161
6/25/2013	5-6, 7-10	39th & 43rd	408
7/1/2013	11-18, 1-4	39th & 43rd	486
7/12/2013	5-6, 7-10	39th & 43rd	184
7/15/2013	1-4,11-18	39th&43rd	468
7/22/2013	5-6,7-10	39th&43rd	377

Total Miles Driven

26827

Avg. Miles Per Cycle

471

truck down

manager's truck

261 miles on manager's truck

7/29/2013	1-4,11-18	39th&43rd	409
8/5/2013	5-6, 7-10	39th&43rd	355
8/12/2013	1-4,11-18	39th&43rd	509
8/19/2013	5-10	39th&43rd	701
9/3/2013	11-18, 1-2-3	39th & 43rd	369
9/9/2013	5-10	43rd only	133 big rain
9/23/2013	5-10	39th & 43rd	394
9/30/2013	11-18, 1-4	39th & 43rd	393
10/7/2013	5-6, 7-10	39th & 43rd	134 used mg. ford
10/9/2013	5 and 8	39th only	289
10/14/2013	11-18, 1-4	39th & 43rd	408
10/21/2013	5-6, 7-10	39th & 43rd	311
10/28/2013	11-18, 1-4	39th & 43rd	371

Monthly Kilowatz Report

39th Ave Pump	
Month	Kilowatz
Jul	115,352
Aug	60,974
Sep	84,792
Oct	126,960
Nov	56,080
Dec	21,840
Jan	19,920
Feb	32,160
Mar	49,200
Apr	158,000
May	126,640
Jun	106,720
Jul	108,640
Aug	40,720
Sept	62,160
Oct	52,400

43rd Ave Pump	
Month	Kilowatz
Jul	117,521
Aug	82,215
Sep	96,640
Oct	96,720
Nov	74,640
Dec	17,680
Jan	56,880
Feb	36,080
Mar	67,520
Apr	57,600
May	0
Jun	72,720
Jul	104,160
Aug	90,560
Sept	52,160
Oct	83,200