

39th Ave Pump Report

Irrigation Dates	Actual GPM	Design GPM	% of Flow	
7/1/2013	2425	2400	101%	
7/12/2013	2435	2400	101%	
7/15/2013	2426	2400	101%	
7/22/2013	2461	2400	103%	
7/29/2013	2418	2400	101%	
8/6/2013	2211	2400	92%	
8/12/2013	2203	2400	92%	
8/19/2013	2150	2400	90%	
9/3/2013	2302	2400	96%	
9/9/2013	2300	2400	96%	
9/25/2013	2301	2400	96%	
9/30/2013	2330	2400	97%	
10/7/2013	2430	2400	101%	
10/9/2013	2457	2400	102%	
10/14/2013	2288	2400	95%	
10/21/2013	2258	2400	94%	
10/28/2013	2362	2400	98%	
11/4/2013	2310	2400	96%	
11/11/2013	2305	2400	96%	
11/18/2013	2326	2400	97%	
12/2/2013	2339	2400	97%	
12/9/2013	2414	2400	101%	
12/27/2013	2208	2400	92%	
12/30/2013	2400	2400	100%	
1/2/2014	2302	2400	96%	
1/6/2014	2301	2400	96%	
1/20/2014	2294	2400	96%	
1/27/2014	2289	2400	95%	
2/10/2014	2353	2400	98%	
2/17/2014	2362	2400	98%	
3/17/2014	2298	2400	96%	
3/24/2014	2285	2400	95%	
4/7/2014	2288	2400	95%	
4/14/2014	2327	2400	97%	
4/21/2014	2306	2400	96%	
4/28/2014	2313	2400	96%	
5/5/2014	2281	2400	95%	
5/12/2014	2283	2400	95%	
5/19/2014	2278	2400	95%	
5/27/2014	2243	2400	93%	
6/2/2014	2220	2400	92%	
6/9/2014	2219	2400	92%	
6/16/2014	2280	2400	95%	
6/23/2014	2282	2400	95%	
				2014
				Total Pump Hours Ran
				1124.90
				Total Gallons Pumped
				154,358,000
				Acre Foot of Water
				473.68

43rd Ave Pump Report

Irrigation Dates	Actual GPM	Design GPM	% of Flow	
7/1/2013	2050	2400	85%	
7/12/2013	2088	2400	87%	
7/15/2013	2083	2400	87%	
7/22/2013	2079	2400	87%	
7/29/2013	2078	2400	87%	
8/5/2013	2112	2400	88%	
8/12/2013	2079	2400	87%	
8/19/2013	2096	2400	87%	
9/3/2013	2090	2400	87%	
9/9/2013	2234	2400	93%	
9/23/2013	2103	2400	88%	
9/30/2013	2098	2400	87%	
10/7/2013	2110	2400	88%	
10/14/2013	2072	2400	86%	
10/21/2013	2094	2400	87%	
10/28/2013	2080	2400	87%	
11/4/2013	2076	2400	86%	
11/11/2013	2077	2400	87%	
11/18/2013	2086	2400	87%	
12/2/2013	2103	2400	88%	
12/9/2013	2107	2400	88%	
12/30/2013	2135	2400	89%	
1/2/2014	2131	2400	89%	
1/6/2014	2130	2400	89%	
1/20/2014	2319	2400	97%	2 new impellers
1/27/2014	2305	2400	96%	
2/10/2014	2326	2400	97%	
2/17/2014	2322	2400	97%	
3/17/2014	2329	2400	97%	
3/24/2014	2322	2400	97%	
4/7/2014	2264	2400	94%	
4/14/2014	2337	2400	97%	
4/21/2014	2300	2400	96%	
4/28/2014	2315	2400	96%	
5/5/2014	2292	2400	95%	
5/12/2014	2302	2400	96%	
5/19/2014	2288	2400	95%	
5/27/2014	2301	2400	96%	
6/2/2014	2284	2400	95%	
6/9/2014	2296	2400	96%	
6/16/2014	2281	2400	95%	
6/23/2014	2290	2400	95%	

2014

Total Pump Hours Ran

1366.60

Total Gallons Pumped

187,928,000

Acre Foot of Water

576.69

Acre Feet Report

39th Ave Pump	
Month	Acre Feet
Jul '13	153
Aug	57
Sep	87
Oct	104
Nov	68
Dec	56
Jan '14	67
Feb	41
Mar	45
Apr	105
May	106
Jun	109

43rd Ave Pump	
Month	Acre Feet
Jul '13	148
Aug	130
Sep	75
Oct	118
Nov	86
Dec	58
Jan '14	94
Feb	51
Mar	62
Apr	121
May	122
Jun	127

Monthly Kilowatz Report

39th Ave Pump

Month	Kilowatz
Jul	108,640
Aug	40,720
Sep	62,160
Oct	74,960
Nov	48,960
Dec	40,240
Jan	47,520
Feb	29,040
Mar	32,240
Apr	75,280
May	76,000
Jun	78,640

43rd Ave Pump

Month	Kilowatz
Jul	104,160
Aug	90,560
Sep	52,160
Oct	83,200
Nov	61,200
Dec	40,720
Jan	65,120
Feb	35,120
Mar	42,880
Apr	83,920
May	84,960
Jun	88,720

Mileage Report

Date	Lines	Pumps	Miles		2014 Miles Driven
7/1/2013	11-18, 1-4	39th & 43rd	486		7037
7/12/2013	5-6, 7-10	39th & 43rd	184	261 miles on manager's truck	
7/15/2013	1-4,11-18	39th&43rd	468		
7/22/2013	5-6,7-10	39th&43rd	377		Avg. Miles Per Cycle
7/29/2013	1-4,11-18	39th&43rd	409		352
8/5/2013	5-6, 7-10	39th&43rd	355		
8/12/2013	1-4,11-18	39th&43rd	509		
8/19/2013	5-10	39th&43rd	701		
9/3/2013	11-18, 1-2-3	39th & 43rd	369		
9/9/2013	5-10	43rd only	133	big rain	
9/23/2013	5-10	39th & 43rd	394		
9/30/2013	11-18, 1-4	39th & 43rd	393		
10/7/2013	5-6, 7-10	39th & 43rd	134	used mg. ford	
10/9/2013	5 and 8	39th only	289		
10/14/2013	11-18, 1-4	39th & 43rd	408		
10/21/2013	5-6, 7-10	39th & 43rd	311		
10/28/2013	11-18, 1-4	39th & 43rd	371		
11/4/2013	5-6, 7-10	39th & 43rd	274	86Mileageford	
11/11/2013	11-18, 1-4	39th & 43rd	182	94milesrepair	
11/18/2013	5-6, 7-10	39th & 43rd	258		
12/2/2013	11-18, 1-4	39th & 43rd	286		
12/9/2013	5-6, 7-10	39th & 43rd	216		
12/27/2013	13	39th only	0	15 min flush of 39th mainline	
12/30/2013	11-18, 1-4	39th & 43rd	173		
1/2/2014	11-18, 1-4	39th & 43rd	172		
1/6/2014	5-6, 7-10	39th & 43rd	294		
1/20/2014	11-18, 1-4	39th & 43rd	339	new truck	
1/27/2014	5-6, 7-10	39th & 43rd	322		
2/10/2014	11-18, 1-4	39th & 43rd	375		
2/17/2014	5-6, 7-10	39th & 43rd	268		
3/17/2014	11-18, 1-4	39th & 43rd	441		
3/24/2014	5-6, 7-10	39th & 43rd	306		
4/7/2014	11-18, 1-4	39th & 43rd	401		
4/14/2014	5-6, 7-10	39th & 43rd	310		
4/21/2014	11-18, 1-4	39th & 43rd	430		
4/28/2014	5-6, 7-10	39th & 43rd	352		
5/5/2014	11-18, 1-4	39th & 43rd	424		
5/12/2014	5-6, 7-10	39th & 43rd	348		
5/19/2014	11-18, 1-4	39th & 43rd	398		
5/27/2014	5-6, 7-10	39th & 43rd	355		
6/2/2014	11-18, 1-4	39th & 43rd	387		
6/9/2014	5-6, 7-10	39th & 43rd	343		
6/16/2014	11-18, 1-4	39th & 43rd	390		
6/23/2014	5-6, 7-10	39th & 43rd	382		